

કૃષિ અને સહકાર વિભાગ
ક્રમાંક.....
12/1/2014
સંખ્યા.....118606

પત્ર ક્રમાંક: પરચ-૧૦૨૦૧૩-૩૮૨-૯ (ભાગ-૨)
શહેરી વિકાસ અને શહેરી ગૃહનિર્માણ વિભાગ
સરદાર ભવન, બ્લોક નં. ૧૪, ૯ મો માળ,
સચિવાલય, ગાંધીનગર
તા.૦૪-૦૨-૨૦૧૪

વિષય:- ગુજરાત અગ્નિનિવારણ અને જીવન સુરક્ષા નિયમો, ૨૦૧૪ અંગે.

ઉપરોક્ત વિષય પરત્વે આજ્ઞાનુસાર જણાવવાનું કે, ગુજરાત અગ્નિનિવારણ અને જીવન સુરક્ષા કાયદો ૨૦૧૩ હેઠળ ગુજરાત અગ્નિનિવારણ અને જીવન સુરક્ષા નિયમો, ૨૦૧૪ તા.૨૦/૦૧/૨૦૧૪ ના જાહેરનામાં ક્રમાંક: જીએચ/વી/૧૧ ઓફ ૨૦૧૪/પરચ-૧૦૨૦૧૩-૩૮૨-૯ (ભાગ-૨) થી પ્રસિધ્ધ કરી વાંધા/સુચનો માંગવામાં આવેલ છે જેની નકલ આ સાથે સામેલ છે. સદરહુ જાહેરનામાની બહોળી પ્રસિધ્ધિ કરવા વિનંતી છે.

આ અંગે નિયત સમયમર્યાદામાં જો કોઈ વાંધા સુચનો મળે તો તે અત્રે મોકલી આપવા પણ વિનંતી છે.

પ્રતિ:-

- (૧) માન. રાજ્યપાલશ્રીના સચિવશ્રી, રાજભવન, ગાંધીનગર
- (૨) માન. મુખ્યમંત્રીશ્રીના અગ્રસચિવશ્રી, માન. મુખ્યમંત્રીશ્રીનું કાર્યાલય, સચિવાલય, ગાંધીનગર
- (૩) અંગત સચિવશ્રી, માન. મંત્રીશ્રી (શ.વિ.) નું કાર્યાલય, સચિવાલય, ગાંધીનગર
- (૪) માન. મંત્રીશ્રીઓના અંગત સચિવશ્રીઓ (તમામ)
- (૫) સચિવાલયના તમામ વિભાગો
- (૬) મુખ્ય નગર નિયોજકશ્રી, ગુજરાત રાજ્ય, ગાંધીનગર
- (૭) જીલ્લા કલેક્ટરશ્રીઓ (તમામ)
- (૮) જીલ્લા વિકાસ અધિકારીશ્રીઓ (તમામ)
- (૯) મ્યુનિસિપલ કમિશ્નરશ્રીઓ, મહાનગરપાલિકા (તમામ)
- (૧૦) મુખ્ય કારોબારી અધિકારીશ્રીઓ, શહેરી / વિસ્તાર વિકાસ સત્તામંડળ (તમામ)
- (૧૧) મુખ્ય કારોબારી અધિકારીશ્રી, ગુજરાત સ્ટેટ ડીઝાસ્ટર મેનેજમેન્ટ ઓથોરીટી (જીએસડીએમએ), ઉદ્યોગ ભવન, ગાંધીનગર
- (૧૨) નગરપાલિકા નિયામકશ્રી, ગુજરાત રાજ્ય, ગાંધીનગર
- (૧૩) ચીફ ઓફિસરશ્રી, નગરપાલિકાઓ (તમામ) (નિયામકશ્રી, નગરપાલિકા મારફત)
- (૧૪) મેનેજીંગ ડીરેક્ટરશ્રી, ગુજરાત અર્બન ડેવલપમેન્ટ કંપની (જી.યુ.ડી.સી.), ગાંધીનગર
- (૧૫) મેનેજીંગ ડીરેક્ટરશ્રી, ગુજરાત અર્બન ડેવલપમેન્ટ મીશન (જી.યુ.ડી.એમ.), ગાંધીનગર
- (૧૬) સેન્ટર ફોર એન્વાયરમેન્ટલ પ્લાનીંગ એન્ડ ટેકનોલોજી (સેપ્ટ), કસ્તુરભાઈ લાલભાઈ કેમ્પસ, યુનિવર્સિટી રોડ, અમદાવાદ
- (૧૭) વિભાગની તમામ શાખાઓ
- (૧૮) લ-શાખા સિલેક્ટ ફાઈલ (૨૦૧૪)

૨૬/૧૩-૩
૧૩/૧૨/૧૪

સેક્શન અધિકારી


શહેરી વિકાસ અને શહેરી ગૃહનિર્માણ વિભાગ

ક્રમાંક:પરચ/૧૩૨૦૧૪/૨૬૮/મ.૩
કૃષિ અને સહકાર વિભાગ
સચિવાલય, ગાંધીનગર
તા. ૦૬/૦૩/૨૦૧૪

પ્રતિ,

વિભાગ હેઠળના સર્વે ખાતાના વડા / બોર્ડ / નિગમ / કૃષિ યુનિવર્સિટીઓ

ઉક્ત બાબતે જાણ તેમજ જરૂરી કાર્યવાહી કરવા સારું.


સેક્શન અધિકારી
કૃષિ અને સહકાર વિભાગ

NOTIFICATION

Urban Development and Urban Housing Department

Sachivalaya, Gandhinagar.

Dated the 20th January, 2014.

Gujrat Fire
Prevention and
Life Safety
Measures
Act, 2013.

No.GH/V/11 of 2014/PRCH-102013-382_L(Part-2):- The following draft of rules which is proposed to be issued under section 57 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11of 2013) is published as required by sub-section (1) of the said section 57 for the information of all the persons likely to be effected thereby and notice is hereby given that the said draft of rules will be taken into consideration by the Government of Gujarat from or after expiry of sixty days from the date of publication of this notification in the *Official Gazzette*.

2. Any objections or suggestions which may be received by the Additional Chief Secretary to the Government of Gujarat, Urban Housing and Urban Development Department Sachivalaya Gandhinagar from any person with respect to the said draft on or before the expiry of the aforesaid period will be considered by the Government of Gujarat.

DRAFT NOTIFICATION

Gujrat Fire
Prevention and
Life Safety
Measures
Act, 2013.

No. GH/V/ 11 of 2014/PRCH-102013-382-L(Part-2):- in exercise of the powers coferred by section 57 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11of 2013), the Governement of Gujarat hereby makes the following rules, namely:-

CHAPTER I PRELIMINARY

1. *Short Title, Extent and Commencement.*- (1) These rules may be called the Gujarat Fire Prevention and Life Safety Measures Rules, 2014.
(2) It extends to the whole of the State of Gujarat.

(3) It shall come into force on the date of their publication in the *Official Gazette*.

2. **Definitions.** - (1) In these rules, unless the context otherwise requires:-

(a) "Act" means the Gujarat Fire Prevention and Life Safety Measures Act, 2013. (Guj. Act No. 11 of 2013);

(b) "Fire Prevention Wing" means the Fire Prevention Wing created under rule 38;

(c) "Fire Safety Certificate" means the Fire Safety Certificate issued under sub-rule (1) of rule 23;

(d) 'Form' means 'Form' in appended to these rules;

(e) "Gujarat State Institute for Fire Safety Training" means Gujarat State Institute for Fire Safety Training, (GSIFST) established under sub-section (1) of section 17 of the Act;

(f) 'Schedule' means a 'Schedule' appended to these rules;

(2) The words and expressions not defined in these rules but defined in the Act, or GDCR or National Building Code of India or relevant Indian Standards or Specifications published by Bureau of Indian Standards shall have the meanings as assigned to them in the Act or Building Bye-laws or National Building Code of India, 2005 or relevant Indian Standards or Specifications published by the Bureau of Indian Standards for construction and fire safety of buildings or premises and *pandals*.

CHAPTER II ORGANISATION, ESTABLISHMENT AND ADMINISTRATION

3. **Qualifications of the Nominated Officer.**- (1) For appointment of the nominated officer under clause (u) of sub-section

(1) of section 2 of the Act, a person shall possess the qualifications as specified in First Schedule.

4. *Equipments and Appliances for Fire Service.*- (1) The Director shall determine the requirement of equipments and appliances for rescue, fire fighting, personal protection in such numbers and with such specifications taking into consideration the apprehension of fire risk in the area for effective measures of safety and efficient response in times of emergency.

(2) The Director, with the previous sanction of the Government, shall procure equipments and appliances determined under sub-rule (1) in such manner that each fire division is adequately equipped to meet with the requirement of fire fighting and fire safety measures and make all necessary arrangements for their upkeep and maintenance to ensure their availability to provide fire prevention and fire safety service as and when required.

(3) The life of equipments and appliances shall be as per the recommendations of the Standing Fire Advisory Council of the Ministry of Home Affairs, Government of India or of any other authority as may be authorized by the Government for this purpose.

5. *Construction or hiring of places for Fire Stations.*- (1) The Director shall identify the area where the establishment of a fire station is tactically advantageous to provide fire prevention and life safety measure.

(2) The Director with the previous sanction of the State Government shall require the local authority to provide land on payment of such premium as may be fixed by the State Government.

(3) The State Government may hire any building or premises on payment of such rent and on such terms and conditions as may be agreed to by both the parties where no land is made available by the local authority.

(4) The composition of the fir station alongwith the staff pattern and facilities to be provided by a fire station may be decided by the Director, depending upon the circumstances prevailing and apprehension of fire risk in the area.

6. *Qualifications for appointment of Fire Officer of different ranks and other terms and conditions of service.*- (1) The qualifications for appointment and other conditions of services of Fire Officer of different ranks shall be, specified by the as the State Government, by any general or special order in that behalf.

7. *Restrictions respecting right to form association, etc.*- No member of the Fire Service shall participate in, or address, any meeting or take part in any demonstration organised by any person or persons for any political purposes or for such other purposes as may be prescribed.

8. *Badges of Ranks in Fire Service.*- Personnels serving at different ranks in any fire service shall have the badges of various ranks as specified in the Second Schedule.

CHAPTER III LICENSED AGENCY

9. *Eligibility for Licensed Agency.*- No person shall be eligible to apply for grant of licence to act as a Licensed Agency unless he,—

(a) possesses atleast any of the following qualifications, namely :—

(i) a degree or Advanced Diploma or Diploma in Fire Engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India; or

(ii) Fellow of Fire Engineering of the Institution of Fire Engineering (U.K.) or M.I. Fire (U.K.) or A.I.V.I.E. Fire India, Graduateship Examination of the Institution of Fire Engineering (U.K.) or the Institution of Fire Engineering (India); and

(b) a degree or diploma in Mechanical or Electrical or Electronics or Chemical or Civil, Engineering obtained from a University established

or incorporated by an Act of the Parliament or a State Act in India or an educational institution; or declared as deemed to be University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); and

- (c) holds a solvency certificate for an amount as may be specified by the Director, with prior approval of the State Government; and
- (d) has the experience of 3 years immediately preceding the year of making the application, executed the work in field relating to fire prevention and fire protection system or holds a certificate of fire protection specialist awarded by the Gujarat State Institute for Fire Safety Training, (GSIFST) established by the Government; and
- (e) has not been black-listed by any Government Department or authority established by a law of the State Legislature; or any board or corporation or organisation owned or controlled by the State Government or any other State Government.

10. *Application for to act as Licensed Agency*:-- (1) Any person who intends to act as a Licensed Agency as specified under sub-section (2) of section 28 shall make an application in "Form A1" for obtaining licence. Such application may be made in person or be sent by registered post acknowledgement or through courier agency or online.

(2) The application made under sub-rule (1) shall be accompanied by fees and fulfill other requirements as specified in the Table below:

TABLE

Class of local authority	Minimum solvency certificate for (Rs in lakhs)	Prescribed limit for execution of the works as per estimated cost (Rs in lakhs)	Cost of annual works minimum executed in the last three years (Rs in lakhs)			Registration fees (Rs in lakhs)
			Fire fighting installations such as hydrants, sprinklers, pumping etc.	Detention of fire separation systems	Passive protection such as	
(1)	(2)	(3)	(4)	(5)	(6)	(7)
Municipal Corporation	25.0	Unlimited	1500	600	600	50000

/ Special Investment Regions/ Industrial Estates						
A	15.0	Unlimited	500	200	200	25000
B	10.0	1000	300	100	100	15000
C	5.0	600	200	50	50	5000
D						
For remaining Gram Panchayat areas	2.5	300	100	25	25	2500

(3) The Applicant shall attach the following documents, namely:-

- (i) solvency certificate for an appropriate amount as specified in column (2) of Table shown above;
- (ii) attested copy of partnership deed and power of attorney or articles of association and memorandum of association or affidavit on stamp paper in case the individual is the sole proprietor of the firm;
- (iii) certificates regarding satisfactory completion of works carried out in last three years issued by the concerned department;
- (iv) orders of works in hand in current year (upto the prescribed amount for that class);
- (v) certificate from the Chartered Accountant or registered Income Tax Practitioner in the prescribed form in case of private works;
- (vi) if the application for registration is made for the first time for a specific class, the applicant is required to have executed at least one work upto the maximum amount in the class, which falls by one class below the specific class, applied for;
- (vii) certificate regarding appointment of at least one officer possessing any of the qualifications specified in clause (b) of sub- rule (1);
- (viii) attested passport size photographs of partners or directors or individual proprietor and also of the officer or officers referred to in the application;
- (ix) affidavit on appropriate stamp paper, stating that his/ her firm is not black listed by any of the departments of

the State Government, local authority or any board or corporation or organisation owned or controlled by the State Government or any other State Government;

(x) list of technical staff with their qualifications; and

(xi) such other information and/or documents as may be required by the Director.

11. *Licence to act as Licensed Agency.*—The application made under rule 10 shall be scrutinised by the Director in accordance with the rules and on being satisfied that the applicant fulfills all the criteria for grant of licence to work as licensed agency, he shall grant the Licence in "Form-A2" to act as Licensed Agency subject to the following terms and conditions, namely:—

(1) The licence shall be—

(a) non-transferable,

(b) valid for two year from the date of issue, unless suspended or cancelled earlier;

(c) renewable for further period of two years, if so desired, before expiry of the licence.

(2) Changes, if any, in respect of

(a) partners, director & or members,

(b) address of the office of the Licensed Agency.

shall be forthwith reported to the Authority issuing the licence.

(3) The Licensed Agency shall always keep the work, executed, or being executed by it, open for inspection by the Director, Chief Fire Officer or any fire officer authorised by the Director or the Chief Fire Officer.

12. *Renewal of Licence.*—An application for renewal of a licence granted under rule 11 shall be required to be made made in "Form-A1" which shall be accompanied by a fee as specified under sub-rule (2) of rule 10 and also documents as mentioned in sub-rule (3) of rule 10.

13. *Notice to showcause as why licence be not suspended or cancelled.* — Where any person to whom the Licence has been granted contravenes any of the provisions of the Act or of the rules or fails to comply with the conditions of the licence or becomes unfit by reason of incompetency, misconduct or any other grave reasons, a notice in "Form-A3" shall be given to such person to showcause as to why the licence granted to him to act as Licensed Agency should not be suspended or cancelled.

CHAPTER IV PROVISIONS RELATING TO FIRE PREVENTION AND LIFE SAFETY MEASURES

14. *Certificates to be issued by a licensed agency.*- (1) A certificate regarding the compliance of the fire prevention and life safety measures in a building or a part thereof as required by or under the provisions of the Act, shall be issued by a Licensed Agency in "Form-B1".

(2) The Licensed Agency shall issue a certificate in the months of January and July in each year regarding the maintenance of fire prevention and life safety measures in a building or premises being in good repair and efficient condition as specified in sub-section (2) of section 29 of the Act, in "Form-B2".

15. *Notice for the removal of objects or goods likely to cause the risk of fire.*- For the purpose of removal of objects or goods likely to cause the risk of fire, a notice in "Form-B3" shall be issued to the owner or occupier of building or premises, by the officer authorized in this behalf, directing him to remove, the objects or goods likely to cause the risk of fire, to a place of safety within a period of as specified in the notice.

(2) On failure to comply with the directions given under sub-rule (1), a further notice in "Form B4" shall be given under sub-section (2)

25

of section 22 to submit his reply as to why the objects or goods should not be seized, detained or removed.

16. *Memorandum of seizure, etc. and panchanama.*—Where any objects or goods involving risk of fire are required to be seized, detained or removed under sub-section (2) of section 22, the memorandum of seizure, etc. shall be prepared in the "Form B5" and the *panchanama* shall be made in "Form B6".

17. *Notice for entry and inspection.* —(1) The notice to be given for entering and inspection required to be given under sub-section (1) of section 24 of the Act for ascertaining the adequacy or contravention of fire prevention and life safety measures in any place or building or part thereof, shall be in "Form B7".

(2) The notice under sub-section (1) of section 24 of the Act to a woman, who according to the custom does not appear in public, shall be given in "Form B8".

18. *Report of Inspection.*— The report of the nominated officer relating to inspection carried out by him under sub-section (5) of section 24 of the Act shall be given in "Form B9".

19. *Notice to the owner or occupier of a building or part thereof to undertake certain measures.* — (1) On completion of the inspection of a place or building or a part thereof, any deviation from, or contravention of, the requirements with regard to the fire prevention and life safety measures or any inadequacy or non-compliance of such measures provided or to be provided therein with reference to the height of the building or the nature of the activities carried on in such place or building or part thereof, are noticed, the owner or occupier of such place or building or part thereof shall be given a notice in "Form-B10", by the officer authorized in this behalf, under section 24 of the Act, directing him to undertake the requisite measures within seven days.

(2) The time to be specified in the notice given to the owner or the occupier under sub-rule (1) shall be specified having regard to the

nature of the measures to be taken but no such time shall exceed 120 days in any case.

20. *Procedure for sealing of a place or building or a part thereof.*- The procedure to be followed by the Director or the Regional Fire Officer or the Chief Fire Officer in regard to sealing of any place or building or part thereof, as required under sub-section (3) of section 26 of the Act shall be as follows, namely:-

- (a) he shall require the persons, in possession or occupation of the place or building or part thereof to be sealed, to remove themselves from there forthwith;
- (b) in case of non-compliance of the said order, he shall direct any police officer having jurisdiction in the area to remove such persons from such place or building or part thereof;
- (c) after the removal of persons in possession or in occupation from such place or building or part thereof, he shall cause such place or building or part thereof to be sealed by such police officer forthwith in the manner which he deems fit;
- (d) the seal used to seal as aforesaid shall remain in the custody of the Director or, the Regional Fire Officer or the Chief Fire Officer, as the case may be;
 - (i) if the place or building or part thereof required to be sealed on receipt of the report of the nominated officer, is found to be locked or inaccessible, he may break to open with the assistance of the police officer and enter the premises and after taking all necessary steps required to be taken under the Act, or under these rules, relock and cause it to be sealed as aforesaid;
 - (ii) where a place or building or a part thereof is sealed under sub-clause (i), an inventory of the material found in such place or building or part thereof shall be prepared in the presence of two independent witnesses and a copy

59

thereof shall be delivered to the owner or occupier, if present at the site. The "Form B5" for inventory and "Form B6" for panchanama, respectively, shall be used for preparation of the reports;

(iii) he shall make report in writing to the Police Inspector of the concerned Police Station if the seal so fixed on any place or building or part thereof is found to be broken or tampered.

21. Appointment of Fire Safety Officer.- (1) For the purpose of effective fire prevention and life safety measures, every owner or occupier or every factory shall appoint a fire safety officer, within a period of six months from the commencement of the Act, having prescribed qualifications and thereafter shall send the compliance report to that effect in Form B11 to the Regional Fire Officer or the Chief Fire Officer.

(2) On the receipt of the compliance report made under sub-rule(1), the Regional Fire Officer or the Chief Fire Officer, shall after due verifications, issue a certificate of enrolment of appointment of the fire safety officer, under the seal and signature of the Regional Fire Officer or the Chief Fire Officer or any other authority in "Form 'B12'".

(3) In case of failure to appoint a fire safety officer as specified in sub-rule (1), the Regional Fire Officer or the Chief Fire Officer shall, after giving an opportunity of being heard, if it is considered to do so, communicate to the relevant authority or to the labour commissioner to take appropriate action for the discontinuance of the use or closure of the building or premises or the factory, as the case may be.

(4) The classification of buildings or premises and the qualifications of the Fire Safety Officer shall be as specified in the Third Schedule;

22. Minimum standards for fire prevention and fire safety for buildings or premises.- (1) The minimum standards for fire prevention

and fire safety for buildings or premises required under sub-section (2) of section 18 of the Act, with respect to the height of the buildings and class of occupancy as provided in the building bye-laws or National Building Code of India, shall *mutatis-mutandis* apply in the following matters, namely:-

- (a) access to building,
- (b) number, width, type and arrangement of exits,
- (c) protection of exits by means of fire check door (s) and or pressurization,
- (d) compartmentation,
- (e) smoke management system,
- (f) fire extinguishers,
- (g) first-aid hose reels,
- (h) automatic fire detection and alarming system,
- (i) public address system,
- (j) automatic sprinkler system,
- (k) internal hydrants and yard hydrants,
- (l) pumping arrangements,
- (m) captive water storage for fire fighting,
- (n) exit signage,
- (o) provision of Lifts,
- (p) standby power supply,
- (q) refuge area,
- (r) fire control room,
- (s) special fire protection systems for protection of special risks:

Provided that classes of occupancies or buildings or premises for which fire prevention and fire safety measures are not provided in the building bye-laws or National Building Code of India, the Director may require the owner or occupier of such occupancies or buildings or premises to provide fire prevention and fire safety measures in accordance with the international standards as may be provided by the Fire Prevention Wing:

5

Provided further that where the Government is of the opinion that it is necessary or expedient to do so, it may, by order, for reasons to be recorded in writing, relax or modify or annul any requirement concerning fire prevention and fire safety measures under these rules with respect to any class of occupancy in any building or premises in special areas or in respect of any building or premises in any area that was constructed or which was under construction prior to the date of commencement of these rules.

(2) Where the Regional Fire Officer or the Chief Fire Officer is of the opinion that it is necessary or expedient to do so, it may, for reasons to be recorded in writing, require the owner or occupier of the buildings or premises to provide additional fire prevention and fire safety measures.

23. *Issuance of Fire Safety Certificate.* - (1) The Regional Fire Officer or the Chief Fire Officer or any other officer (s) authorised by him in this behalf by a general or special order shall issue a Fire Safety Certificate in "Form B13" to the owner or occupier of the building or premises with such conditions as may be specified in the Fire Safety Certificate for compliance of fire prevention and fire safety measures as specified under these rules.

(2) The application for grant of Fire Safety Certificate shall be made to the Regional Fire Officer or the Chief Fire Officer in "Form B14" and shall be accompanied with a certificate from the architect and owner or occupier to the effect that all the fire prevention and fire safety measures as required under rule 22 have been incorporated in the building or premises.

(3) On receipt of the application made under sub-rule (2), the building or premises shall be inspected by the Fire Officers to ascertain the availability and operability of the fire prevention and fire safety measures who shall send his report with recommendation to the Regional Fire Officer or the Chief Fire Officer for grant or refusal of fire safety certificate.

(4) On receipt of the recommendations under sub-rule (3), the Regional Fire Officer or the Chief Fire Officer shall grant the fire

safety certificate in the relevant prescribed form or reject the same for reasons to be recorded in writing and communicate to the owner or occupier, as the case may be.

(5) In case of rejection of application for grant of fire safety certificate under sub-rule (4), a fresh application shall be made by the owner or occupier under sub-rule (2) duly complying with the requirements as communicated under sub-rule (4).

(6) The buildings or premises that have already been issued 'No Objection Certificate' for the occupancy of the building or premises shall deemed to have been issued 'Fire Safety Certificate' under rule 23 subject to verification of compliance of fire prevention and fire safety measures on which the 'No Objection Certificate' was issued on the last occasion.

24. Duration of Fire Safety Certificate.- The fire safety certificate issued under rule 23 unless sooner cancelled shall be valid for a period of 5 years for residential buildings (other than hotels) and 3 years for non-residential buildings including hotels from the date of issue:

Provided that the Regional Fire Officer or the Chief Fire Officer may reduce the period after recording the reasons therefore.

25. Renewal of Fire Safety Certificate.- (1) Application for renewal of Fire Safety Certificate granted under rule 23 shall be made to the Regional Fire Officer or the Chief Fire Officer, in Form 'B14' along with a copy of the Fire Safety Certificate prior to one month before of the expiry date of the Fire Safety Certificate.

(2) On receipt of an application made under sub-rule (1), the Regional Fire Officer or the Chief Fire Officer or any other officer authorised by him shall inspect the building or premises to verify the compliance of rules and forward the report of the compliance or otherwise, to the Director.

(3) On receipt of report under sub-rule (2), the Regional Fire Officer or the Chief Fire Officer or any other officer authorised by him in this behalf by a special or general order, renew the Fire Safety

54

Certificate for a period specified under rule 24 or reject the application duly recording the reasons therefore.

26. *Liability to maintain fire safety measures.*- (1) The occupier of the building or premises, as the case may be, shall maintain the fire prevention and fire safety measures provided in the building or premises at all times in best repairs for use by the occupants or members of Fire Service or both in the event of an out break of fire.

(2) The occupier of the building or premises or the Fire Safety Officer appointed under section 12 of the Act, as the case may be, shall declare every year in Form 'B15' that fire prevention and fire safety measures provided in the building or premises.

(3) It shall be lawful for the the Regional Fire Officer or the Chief Fire Officer, to enter and inspect the building or premises, as the case may be, with a view to verifying the correctness of the declaration made under sub-rule (2) and to point out the shortcomings, if any, with directions to remove them within a specified time. If the directions of the inspecting officer are not complied within the time limit so given, the inspecting officer with the previous approval of the the Regional Fire Officer or the Chief Fire Officer shall declare the building or premises unfit from fire safety point of view and direct the local body/ authority or any other authority concerned to disconnect the electricity and water supply to the building or the premises, as the case may be, and the local body/ authority or the other authority shall comply with the directions of the inspecting officer.

(4) The owner or the occupier of the building or premises or the Fire Safety Officer, who falsely makes declaration, in contravention of the provision made under sub-rule (2), shall be deemed to be in default and shall be liable to penalty.

CHAPTER V

PROVISIONS FOR TEMPORARY STRUCTURES

27. Minimum standards for fire prevention temporary structure, etc.-

(1) The minimum standards for fire prevention and fire safety for temporary structure such as *mandap, shamiyana or tents or pandal* for the purposes of sub-section (2) of section 27 shall be required in accordance with IS:8758:1993 published by Bureau of Indian Standards, New Delhi and National Building Code of India, relating to the following matters, namely:-

- (a) access temporary structures etc;
- (b) open space around the temporary structures etc;
- (c) distance from medium and high voltage electrical wires and hazardous installations,
- (d) means of exits,
- (e) material of construction,
- (f) first-aid fire fighting arrangements,
- (g) water storage for fire fighting,
- (h) electrical wiring,
- (i) availability of trained fire fighting staff.

(2) The promoter, organizer or the owner or occupier shall require provide and maintain the measures specified in sub-rule (1).

28. Form of declaration.- The erector of temporary structures such as *mandap, shamiyana or tents or pandal* shall, for the purposes of due compliance of sub-section (2) of section 27 of the Act, make a declaration in Form 'C1', to the effect that adequate fire safety measures have been taken as provided in rule 27.

29. Removal of encroachments or objects or goods likely to cause a risk of fire or any obstruction to fire fighting.- (1) The Sub-Divisional Magistrate having jurisdiction may, after giving a reasonable opportunity of being heard as provided by sub-section (7) of section 27 of the Act may order to seize, detain or remove encroachments or objects or goods likely to cause a risk of fire or obstruction to fire fighting.

(2) The order under sub-rule (1) shall be made in Form 'C2' and the panchnama shall be made in Form 'C3'.

(3) The notice to the person in possession of the inventory of the objects or goods as required under sub-section (8) of section 27 of the Act shall be given in Form 'C4'.

30. *Notice to pay the charges for the services rendered by the State Fire Services.*- (1) Where the State Government has provided the services for Fire Prevention and Life Safety Measures, the Director may issue notice in Form C5 requiring the owner or the occupier of the building or premises, to pay the amount for the expenses incurred for rendering the aforesaid services.

31. *Measures to be taken for fire prevention and life safety in temporary structures.*- The measures required to be taken by the promoter, the organizer or the owner or the occupier of premises declared under sub-section (1) of section 27 of the Act, shall be such as specified in sub-rule(1) of rule 27.

(2) The show cause notice to be issued by the Sub-Divisional Magistrate under sub-section (6) of section 27 of the Act shall be as specified in Form C6.

(3) The Regional Fire Officer or the Chief Fire officer may grant permission, in form C8, subject to such conditions, as specified therein, for the use of temporary structures *a shamiyana or tent or mandap*, on receiving the declaration by the promoter or the organizer or the owner or the occupier of premises in form C7, the measures taken by him as specified in sub-rule(1) of rule 27..

(4) The Director or the Regional Fire Officer or the Chief Fire officer or the Nominated officer may, under sub-section (4) of section 27 of the Act, inspect the premises ensuring the correctness of the declaration made in form C7 or otherwise, and in case of inadequacy, give necessary directions to comply, within the specified time, to the promoter or the organizer or the owner or the occupier.

(5) In case of failure to comply any directions given under sub-rule (4) by the said officer may seal or dismantle the temporary structures *a shamiyana or tent or mandapand* recover the cost

incurred thereof from the promoter or the organizer or the owner or the occupier.

(6) The Regional Fire Officer or the Chief Fire officer or any authorized officer, in this behalf, if finds that there exists any encroachment or objects or goods, which may cause or likely to cause a risk of fire or any obstruction to firefighting, he may direct to remove, within specified time, such encroachments or objects or goods.

(7) On failure to comply with the directions given under sub-rule (6), by the the promoter or the organizer or the owner or the occupier, the said officer shall take necessary action as per sub-section (6) of section 27 of the Act.

(8) On receipt of the report given by the Regional Fire Officer or the Chief Fire officer or any authorized officer, of the encroachment or objects or goods, which may cause or likely to cause a risk of fire or any obstruction to firefighting, may make an order in form C2 to seize, detain or remove it.

(9) The person authorized under sub-rule (8), shall give a notice in form C4, to the person in possession, that the goods and objects seized, detained or removed shall be sold if they are not claimed within the time specified in the notice.

(10) Any person aggrieved by an order under sub-rule (7) or a notice issued under sub-rule (8) may prefer an appeal in form C9 which shall be accompanied by a copy of order or notice appealed against and by a fee of Rs. 5,000/- (Rupees five thousand only) through a bank draft drawn in favour of the Director, Gujarat State Fire Service payable at Gandhinagar.

(11) The appellate authority shall consider all the circumstances of the case and after making necessary inquiry as it deem fit pass such orders as it may deem just and proper and his order shall be final.

35

(12) The authority which made the order or issued the notice on which the appeal was preferred shall give effect to the order passed by the appellate authority.

CHAPTER VI TRAINING TO FIRE PERSONNEL

32. *Training Charges.*- The trainee shall pay at the time of admission training charges as specified in the Forth Schedule by demand draft payable to the Principal, Gujarat State Institute for Fire Safety Training, (GSIFST):

Provided that, the trainees on the roll of State Fire Service shall not be liable to pay training charges.

33. *Manner for remittance of training charges.*- (1) The Principal, GSIFST shall remit or cause to remit to the Director, State Fire Service at the end of each course the total sum of the training charges received under the heads of tuition fee, laboratory charges, fire ground operation charges, and accommodation charges.

(2) The Director, shall maintain a separate head for remitting the training charges received and shall utilize the same for providing amenities like sports facilities (indoor and outdoor), and indoor recreation facilities to the trainees.

34. *Training charges to be non-refundable.*- If any trainee decides to withdraw from the course before the date of closing of training schedule for whatever reasons or expelled from the course by the Principal, GSIFST he shall not be entitled to refund of training charges remitted by him under rule 32 in full or part thereof.

35. *Security Deposit.*- (1) On admission of an trainee to a course, if he is allotted accommodation, he shall be required to deposit a sum of rupees one thousand only as security deposit by a bank draft, to the Principal, GSIFST:

Provided that, the trainees on the roll of State Fire Service shall not be liable for payment of Security Deposit.

(2) The security deposit shall be refunded at the end of course after verifying that all articles made available to him are in good condition and no losses has caused to the exchequer during the training by his conduct.

CHAPTER VIII

APPEAL

36. *Appeal.*- (1) An appeal to the Appellate Authority under section 33 of the Act shall be preferred in Form C9 and shall be accompanied by a copy of order or notice appealed against and by a fee of Rs. 5,000/- (Rupees five thousand only) through a bank draft drawn in favour of the Appellate Authority.

(2) The appellate authority shall consider all the circumstances of the case and after making necessary inquiry as it deem fit pass such orders as it may deem just and proper and his order shall be final.

(3) The authority which made the order or issued the notice on which the appeal was preferred shall give effect to the order passed by the appellate authority.

37. *Compounding of offences.*- The offences punishable under the Act, specified in column (2) may be compounded either before or after the institution of prosecution by the officer specified in column (2), for the amount specified in column (3) of the Table below;-

Table

Officer (1)	Offences and Penalties under the Act (2)	Fine Rupees (3)
Regional Fire Officer or the Chief Fire Officer	Sub-section (1) of Section 18	10000
	Sub-section (1) of Section 19	10000
	Sub-section (4) of Section 21	10000
	Sub-section (2) of Section 22	10000
	Sub-section (3) of Section 24	10000
	Sub-section (4) of Section 27	10000
	Sub-section (1) of Section 29	10000
	Sub-section (3) of Section 29	10000

CHAPTER IX
GENERAL MEASURES FOR FIRE PREVENTION

38. *Fire Prevention Wing.*- There shall be constituted a 'Fire Prevention Wing' for the State Fire Service, or for local authority under the Director or the Chief Fire Officer consisting of such other fire officers and other personnels as the State Government may by notification in the *Official Gazette* declare or the local authority may declare by an order, as the case may be.

39. *Powers and Functions of Fire Prevention Wing:* (1) The Fire Prevention Wing or officer authorized by it, shall examine the building plans referred to Fire Service by local authority or any other statutory authority for compliance by the owner or occupier under the regulations made under sub-section(2) of section 18 of the Act.

(2) The Fire Prevention Wing shall have the following powers and functions in addition to sub-rule(1), namely:-

(a) study the trends in fire accidents in the region and assist in framing the policies in the matters connected therewith for the fire prevention and fire safety and similar other matters incidental thereto, requirement and deployment of fire fighting equipment and appliances, planning for new fire stations and prepare training requirements for Fire Service;

(b) study the provisions relating to fire prevention and fire safety as contained in other Acts, Statues, Rules and Regulations for the time being in force;

(c) in consultation with the Government counsel, defend the cases in various courts of law;

(d) organize mass awareness programs on fire prevention and fire safety and prepare leaflets and other advertisement material in electronic form for distribution to the public free of any charges.

40. *Fire Service response to an Emergency.*- The Fire Service response to an emergency arising due to an out break of fire or any other emergency requiring Fire Service intervention shall be carried

out in accordance with the directions given by the Regional Fire Officer.

41. *Issuing of Fire Report.*- (1) A fire report shall be made available on line or otherwise within 72 hours of the date of occurrence of fire to the Director for every fire accident and special service call responded to by the any Fire Service. The owner or occupier whose property was affected by fire or otherwise by whatever way may obtain the copy of report from the Director.

(2) In case owner or occupier requires any change in facts reported in the fire report he or she shall make an application in Form D1 to the Director who may after satisfying himself allow the change requested for and record the same on the fire report.

42. *Adequate supply of water for fire fighting.*- (1) Notwithstanding anything contrary to the provisions in any other Act or rules for time being in force, the Regional Fire Officer or the Chief Fire Officer, as the case may be, may require the authority having jurisdiction to provide hydrants at strategic locations on the public mains or private mains of not less than 150 mm diameter on payment of charges as demanded by such authority.

(2) The residual pressure at the hydrant shall not be less than 1.5 bar (20 lbs. per square inch).

(3) There shall be provided near each hydrant provided under sub-rule (1) an identification plate showing hydrant number and size of mains and each such hydrant shall be maintained by the authority which provided the hydrant.

43. *Directions of Fire Officer relating to supply of electricity or water or removal of persons from, a place or building or part thereof which is in imminent danger:*— (1) The Director or the Regional Fire Officer or the Chief Fire Officer, may make an order under section 26 of the Act, directing the responsible authority,-

assess the damage and submit his recommendations in that behalf to the authority for its consideration.

(3) Having regard to the recommendation made by nominated officer under sub-rule (2), and where the building or property to which such damage is caused is insured, the Insurance Company shall while determining and granting compensation to be paid to the owner or occupier take into account the damage caused to the premises or any other property by the fire officers or fire personnel during the conduct of firefighting and rescue operations.

47. *Report of accident to fire officer or fire personnel during fire and payment of compensation.*- The fire officer in-charge of fire, shall submit a report of any accident occurred during such fire fighting or rescue operations operations, in case of natural calamity or otherwise, to the Director, the Regional Fire Officer or the Chief Fire Officer and the compensation payable to any fire officer, or fire personnel in the case of such accident, or to their dependents in the case of death or permanent disability, shall be such as may be determined by, the Director may with the approval of the State Government or the local authority, as the case may be.

48. *Employment of fire officer or fire personnel for purposes other than fire fighting within or outside the sphere of their duties.*- The fire officers or fire personnel may be engaged for the purposes other than fire fighting at the discretion of the Director or the Chief Fire Officer or any subordinate officer authorized by the Director or the Chief Fire Officer, in the case of all calls relating to natural calamities and rescue of life.

49. *Rates for supply of water required on the occasion of fire fighting operations.*- Where the officer in-charge of the fire fighting operations draws water, from any source in the area, which he considers necessary for such operations, the authority or owner or occupier having control over such water source shall be paid for the water so utilised,—

94

(a) if water is drawn from an authority, then at the lowest rate of supply of water which is usually charged from the users of water in such area by such authority;

(b) if water is drawn from any owner or occupier, then at the rate which shall not exceed the lowest rate referred to in clause (a), and where such rate is not available, then at such rate as may be determined by negotiation, subject, however, to the condition that where any dispute arises as to such rate, in the case of an authority, the decision of the authority competent, and in the case of an owner or occupier, the decision of the Director, shall be final.

50. *Terms for securing personnel or equipment or both for fire fighting purposes.*- The terms on which the Director or the Chief Fire Officer or any other fire officer authorized by any authority may secure, by agreement, fire fighting equipment or personnel from any person who employs and maintains personnel or equipment or both, for fire fighting purposes, shall be as follows, namely:—

(1) As soon as may be, after the fire fighting operation is over, the Director or the Regional Fire Officer or the Chief Fire Officer or any other Fire Officer in charge of the fire fighting operation, as the case may be, shall relieve the personnel or equipment so secured and restore the same to the person, including the local authority, firm and institution or individual, from whom the services of personnels and possession such equipment were secured.

(2) There shall be paid to the employer of such personnel or owner of such equipment, compensation, the amount which is determined in accordance with the principles hereinafter setout, namely:—

(a) where the amount of compensation is determined under the agreement, it shall be paid in accordance with such agreement;

(b) where such compensation is not settled in the agreement or where no such agreement with regard to compensation can be reached, the matter shall be referred to the State Government or the local authority, as the case may be, and the decision of the State Government or the local authority, as the case may be, shall be final;

(c) if any injury is caused to any personnel or any damage is caused to any equipment and the employee or the owner of the equipment, as the case may be, demands any compensation separately in respect thereof, and no agreement can be reached, the matter shall likewise be referred to the State Government or the local authority, as the case may be, for determination and the decision of the State Government or the local authority, as the case may be, shall be final.

51. *Rewards.*- (1) The Director or the local authority, as the case may be, may sanction rewards by way of certificate or cash rewards or with both to the personnels of any Fire Service for meritorious performance of duties, to the extent as specified in the Table below:-

TABLE

Sr. No.	Sanctioning Authority	Type of commendation.	Cash Rewards
(1)	(2)	(3)	(4)
1	Director	Commendation Roll	Up to Rs. 5,000/- in each case for actions of outstanding merit.
2	The Regional Fire Officer or the Chief Fire Officer	Commendation Certificate Class I	Up to Rs. 3,000/- in each case for actions of special merit.
3	The Deputy Chief Fire Officer	Commendation Certificate Class II	Up to Rs. 1,000/- in each case in recognition of specific instances of exemplary performance or assistance to Fire Service on the occasion of fire and/ or rescue:

99

Provided that the State Government or the local authority may on the recommendation of the sanctioning authority, in each case, grant rewards up to Rs. 10,000/- (Rupees ten thousand only) in recognition of specific instances of exemplary performance or assistance by the members of any Fire Service on the occasion of fire and or rescue.

(2) The rewards to the members of Fire Service under sub-rule (1) shall be recorded in the Service Book in green ink by the authority granting such reward.

52. *Power of Director to give directions.*-(1) The Director with the previous approval of the Government, may issue such directions as are necessary for the efficient administration of the fire service which may among others, include the followings, namely:-

- (i) training to members of fire service;
- (ii) discipline and good conduct of members of fire service;
- (iii) speedy attendance of members of fire service with necessary appliances and equipment on the occasion of any alarm of fire;
- (iv) conditions of service of the members of Fire Service;
- (v) assigning duties to fire officers of all ranks and grades, and prescribing the manner in which and the conditions subject to which they shall exercise and perform their respective powers and duties;
- (vi) institution, management and regulation of any Fire Service fund for any purpose connected with policy administration;
- (vii) maintenance of Fire Service equipment and appliances to keep them in due state of efficiency; and
- (viii) generally for the purposes of rendering the Fire Service efficient and preventing abuse or neglect of their duties.

53. *Power of Director to have assistance of police officers.*- The Director or the Regional Fire Officer or the Chief Fire Officer or any other fire officer while performing his duties in Fire Fighting operations or any other duties of seizure, detention or removal of any

goods involving risk of fire may require the assistance of a police officer or members of the police force as an aid in performance of such duties and it will be the duty of police officer of all the ranks or such members to aid the Director or such fire officer in the execution of their duties under this Act.

96

FIRST SCHEDULE

(See rule 3)

Qualifications for the appointment of Nominated Officer

Serial Number	Municipality	Qualifications
(1)	(2)	(3)
	Municipal Corporation	<p>(i) possesses a Degree or an Advanced Diploma in Fire Engineering from the National Fire Service College, Nagpur under the Ministry of Home Affairs, Government of India or the Gujarat State Institute for Fire Safety Training, Government of Gujarat (GSIFST) and at least two years experience of regular fire service for inspection and testing of fire prevention and protection work; or</p> <p>(ii) has passed the Membership Examination of the Institute of Fire Engineers of India or the Institution of Fire Engineers of United Kingdom and has at least two years experience of regular fire service and of fire prevention and protection work.</p>
	Municipalities, or Notified Area or Industrial Townships/Estate.	<p>A Diploma in Fire Engineering obtained from the National Fire Service College, Nagpur under the Ministry of Home Affairs, Government of India or the Gujarat State Institute for Fire Safety Training, Government of Gujarat (GSIFST) and at least two years experience of regular fire service.</p>
	Special Investment Region and Special Economic Zones (SEZs), Private Townships	<p>1. possesses a Degree or an Advanced Diploma in Fire Engineering from the National Fire Service College, Nagpur, Ministry of Home Affairs, Government of India or the Gujarat State Institute for Fire Safety Training, Government of Gujarat (GSIFST), and at least two years' experience of regular fire service for inspection and testing of fire prevention and protection work; or</p> <p>2. has passed the Membership Examination of the Institute of Fire Engineers, India or the Institution of Fire Engineers of United Kingdom and has at least two years' experience of regular fire service and of fire prevention and protection work.</p>

SECOND SCHEDULE

Badges of Ranks in Fire Service

(See rule 8)

1. Badges of Ranks, Peak Cap, Collar Patches and Hemet

Markings.- The Badges of Ranks, Peak Cap, Collar Patches and Hemet Markings for various posts in Fire Service shall be as per the table below:-

Sr. No.	Name of the post	Badges of rank	Collar Patches	Peak Cap	Helmet
1	Director	Cross sword and baton with one small impeller $\frac{3}{4}$ " diameter + Shoulder titles "GSFS".	Blue black collar patches with two rows of oak leaves as per drawing.	Two rows of silver oak leaves on peak embroidered badge and black band placed around the head level.	White with one 38 mm black band.
2	Chief Fire Officer	Ashok emblem with three small impellers $\frac{3}{4}$ " diameter + Shoulder titles "GSFS".	One silver line 7 cm long line on blue blazer cloth.	One row of silver oak leaves on peak, embroidered badge and black band placed around the head level.	White with two 19 mm black bands with 12.5 mm separation.
3	Deputy Chief Fire Officer	Ashok emblem with one small impeller $\frac{3}{4}$ " diameter + Shoulder titles "GSFS".	One silver line 4 cm long line on blue blazer cloth.	One row of silver oak leaves on peak, embroidered badge and black band placed around the head level.	White with three 12.5 mm black bands with 12.5 mm separation.
4	Divisional Officer (Fire)	Ashok emblem + Shoulder titles "GSFS".	Not applicable.	Plain peak with embroidered badge.	White with two 12.5 mm black bands with 12.5 mm separation.
5	Assistant Divisional	Three small impellers $\frac{3}{4}$ " diameter + Shoulder titles "GSFS".	Not applicable	Plain peak with embroidered badge.	White with one 12.5 mm black band.
6	Station	Two small	Not	Plain peak	Yellow with

Sr. No.	Name of the post	Badges of rank	Collar Patches	Peak Cap	Helmet
	Officer	impellers ¾" diameter + Shoulder titles "GSFS".	applicable	with metal badge.	one 12.5 mm black band.
7	Sub-Officer	Two small impellers ¾" diameter with blue strip + Shoulder titles "GSFS".	Not applicable	Plain peak with metal badge.	Yellow.
8	Leading Fireman	One bar ½" wide and 1½" long with semi-circular cross section with flat bottom surface and round surface on top made out of white metal + Shoulder titles "GSFS".	Not applicable	Khaki Beret with metal badge.	Black.
9	Driver	2" diameter, 3 spoked steering wheel embroidered in white on blue black ground + Shoulder titles "DFS".	Not applicable	Khaki Beret with metal badge.	Black.
10	Fire Operator/ Fireman /Fireman Driver.	Shoulder titles "GSFS".	Not applicable	Khaki Beret with metal badge.	Black.

2. **Car Flag and Star Plate.**- (1) The staff car used by the Director shall have displayed on the bonnet a flag made out of blue black blazer cloth and star plate on front and rear side bumper of the staff car as per drawing.

(2) The staff car used by the Chief Fire Officer shall have displayed on the bonnet a flag made out of blue black blazer cloth and star plate on front and rear side bumper of the staff car as per drawing.

THIRD SCHEDULE

(See sub-rule (4) of rule 21)

Classification of Buildings for Appointment of Fire Safety Officer

I. The Fire Safety Officers of different Ranks shall be appointed for different class of buildings namely:

Class of building	Buildings	Rank of Fire Safety Officer
I	<ol style="list-style-type: none">1 cinema houses with seating capacity of more than 1000 persons and having commercial complex with built-up area more than 10000 sq. mtr. and building having multiple cinema with seating capacity, taken together, of 1000 persons, or more, whether, having commercial complexes or not;2 underground shopping complexes, district centers, sub-central business districts, including the basement with build up area of more than 25000 sq. mtr.;3 large oil and natural gas installations such as refineries, LPG bottling plants and similar other facilities;4 open stadia with seating capacity more than 50,000 persons and indoor stadia with seating capacity more than 25,000 persons;5 public and semi-public buildings like large surface and sub-surface railway stations, interstate bus terminuses, airports, amusement parks and other similar buildings;	Deputy Chief Fire Officer
II	<ol style="list-style-type: none">1 hotels with 100 rooms and above;2 multistoreyed non-residential buildings above 50 meters in height;3 hospitals and nursing homes with more than 500 beds;	Divisional Officer (Fire)

CB

8. Class of occupancies likely to cause risk of fire.- the following classes of occupancies for the purposes of sub-section (1) of section 25 of the act shall be construed to likely cause a risk of fire, namely:-

- (a) pandal having seating capacity more than 50 persons or covered area more than 50 square meters.
- (b) residential buildings (other than hotels and guest houses) having height more than 15 meters or having ground plus four upper stories including mezzanine floor.
- (c) hotels and guest houses having height more than 12 meters having ground plus three upper stories including mezzanine floor.
- (d) educational buildings having height more than 9 meters or having ground plus two upper stories including mezzanine floor.
- (e) institutional buildings having height more than 9 meters or having ground plus two upper stories including mezzanine floor.
- (f) all assembly buildings.
- (g) business buildings having height more than 15 meters or having ground plus four upper stories including mezzanine floor.
- (h) mercantile buildings having height more than 9 meters or having ground plus two upper stories including mezzanine floor.
- (i) industrial buildings having covered area on all floors more than 250 square meters.
- (j) storage buildings having covered area on all floors more than 250 square meters.
- (k) all hazardous buildings having covered area on all floors more than 100 square meters.
- (l) underground structures.

9. Height of building.- the minimum height of the buildings for the purposes of sub-section (1) of section 33 and sub-section (1) of section 35 of the act shall be as specified in rule 27.

FOURTH SCHEDULE

Training Charges at Admission to Course

(See rule 32)

1. **Training Charges.**- The training charges to be paid by each external trainee at the time of admission to any course of study conducted at GSIFST or at any other place as may be determined by the Director shall be determined based on the duration of the course in accordance with the table below:

Course Duration (Weeks)	Training Charges (Rs)						Total (Rs) [Excluding accommodation charges]	
	Tuition Fee	Laboratory Charges	Fire Ground operation charges	Accommodation Charges (Rs per week)				Trainees amenities fund
				Barrack	Single	Double		
1	500	--	500	250	1000	500	100	1100
2	1000	--	1000	250	1000	500	200	2200
3	1000	500	1000	250	1000	500	300	2800
4	1500	500	1500	250	1000	500	400	3900
6	2000	1000	3000	250	1000	500	600	6600
12	4000	2000	4000	250	1000	500	1200	11200
24	8000	2000	5000	250	1000	500	2400	17400

2. **Trainees' Amenities Fund to be paid by members of Fire Service.**- All the members of Fire Service undertaking a course of study at GSIFST shall pay the trainees' amenities fund determined under clause (1) at the time of admission.

Revision of Training Charges.- The training charges shall be revised every three years at the rate as may be determined by the Government.

FORM A1

(See sub-rule 1 and rule 10)

Application for Licence to act as Licesance Agency

To,
The Director

Sub: - Application for Licence to act as Licensed Agency

The undersigned hereby applies for grant of or renewal of License to act as a Licensed Agency for undertaking and executing the work of providing installation of equipments and maintenance of fire prevention and life safety measures in any place, building or part thereof. The particulars regarding the Agency arc given below:-

1.	Full Name of the Applicant (In capital letters).	
2.	Whether Licensed Agency will be a Proprietary Concern or an Association of persons such as a Firm or Company, etc.	
3.	Registration No. of Firm or Company (Copies of Registration Certificate, article of Association or other relevant document appended.	
4.	Address	
5.	If the Licensed agency will be: a. a proprietary concern, the name, qualifications and address of the person operating the same. b. a firm or company, names, qualifications and addresses of each of the partners, or as the case may be, Directors.	
6.	Office address from where the Agency will act as a Licensed Agency -	
7.	Class for which Licence is applied for -	
8.	Personnel with the Agency - a. Supervisory staf, name, qualifications and addresses of each. b. Other employees-names, qualifications and addresses of each.	
9.	Details of work with regard to fire Prevention and life safety measures, if any, undertaken and executed prviously: a. Name or nature of work b. Approximate cost of work c. Whether the work executed or still in progress and remains to be executed. (Note.-Original or attested	

	copies of Certificate of verification of above details by the officers under whom works are carried out are attached).	
10	Technical qualifications and and experience of the promoter or partners of directors and dealing technical officers or employees of or with the applicant.	
11	Workshop machinery, tools and plant owned by the applicant, (location and site of workshop and full details to be given).	
12	Whether enlisted with any other department or Organization in any other State. If so, in which category. a. Has the applicant or his partners or Directors been blacklisted in the past by any Government Department/ organization/other State? b. Has the applicant applied for registration elsewhere in his name or in the name of partner, Director or firm or company? If so, whether the application is rejected? Give particulars.	
13	Whether the applicant has produced up to date Income tax certificate.	
14	Amount of solvency certificate, which the applicant has held or produced.	
15	A fee of Rs. _____ remitted herewith by Demand Draft No. Dated. _____ Drawn on _____ Bank.	
16	If the application is for renewal of the existing licence, the details in respect of the licence and the period of its validity. (copy of the licence appended).	
17	Whether, the licence to act as Licensed Agency granted anytime previously has been suspended or cancelled; and if so, reasons therefor:-	

I/We certify that I/We have not been and will not get myself or ourselves registered as contractor in the department under more than one name.

Thanking you,

Yours faithfully

FORM A2

License to act as a Licensed Agency for Fire Prevention and life Safety Measures

(See rule 11)

Licence No.

Date:-

Licence is hereby granted or renewed under the provisions of sub-section (1) of section 28 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Gujarat Act 11 of 2013) to _____ having their registered office at _____

_____ to act as Licenced Agency for the purposes of the said Act for execution of the fire prevention and life safety measures in relation to _____ in class _____ local authority.

Subject to the provisions of sub-section (2) of section 28 of the said Act and rule 20 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013, the licence will be valid for a period from _____ to _____

SEAL OF
THE OFFICE

()

Director

Gujarat.....

Place,

Date :

FORM A3

(See rule 13)

Notice to Licensed Agency for suspension or cancellation of
Licence

To,

WHEREAS a Licence to act as a Licensed Agency for the purposes of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Gujarat Act 11 of 2013), being a licence No. _____ dated _____ has been granted or renewed in the name of and the licence so granted or renewed was subject to the provisions of section 28 of the said Act and the conditions of licence, specified in rule 21 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013;

AND WHEREAS it is noticed that you are guilty of the following acts, namely:-

- (1) _____
- (2) _____
- (3) _____

AND WHEREAS these acts amount to _____

NOW THEREFORE, in exercise of the powers conferred on me by sub-section (1) of section 28 of the said Act (read with sub-section (4) of section 28 of the said Act), I, hereby call upon you to show cause in writing, within a period of 30 days from the receipt of this notice as to why the licence so granted or renewed in your favour should not be suspended or cancelled.

SEAL OF
THE OFFICE

Place:

()

Date:

Director

25

FORM B1

(See sub-rule (1) of rule 14)

Certificate by the Licensed Agency for compliance
of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I/We have executed the works towards compliance in relation to Fire Prevention and Life Safety Measures to be provided and performed other related activities required to be carried out, in the following building or premises, as required under the provisions of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013).

Description and Location of Building or Premises

The details of the work and related activities which I or we have executed or performed are mentioned in the list appended herewith.

Place : Signature and Address of the Licensed Agency.

Date : Licence No

Chief Fire Officer / Regional Fire Officer
/ Nominated Officer

[*Note.- For each building a separate certificate is be necessary].

FORM B2

(See sub-rule (2) of rule 14)

Six monthly certificates to be given by the owner or the occupier for compliance of the Fire Prevention and life Safety Measures

CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely* :—

I /We further certify that these installations in the above mentioned buildings are maintained, in good repair and efficient conditions during the period _____, as under the provisions of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj.11 of 2013). The details of the inspection of installations carried out by me/us are mentioned in the report appended herewith.

Place: _____ Signature and Address of the Licensed _____

Agency: _____

Date: _____ Licence No: _____

Chief Fire Officer / Regional Fire Officer
/ Nominated Officer

[*Note:- detailed location and postal addresses are to be provided here].

FORM B3

(See sub-rule (1) of rule 15)

**Notice for removal of objects or goods likely to cause
the risk of fire.**

To,
Shri

Whereas, Government has, by notification, _____
Department, Notification No. _____ dated _____ published
in the Gujarat Government Gazette, dated _____ required that the
owners or occupiers of premises or any Class of premises used in the
following area, which in its opinion, are likely to cause risk of fire, to
take such precautions as have been specified in the said notifications
and as are reproduced herebelow-

And whereas, you are the owner or occupier of the following
premises, which fall in the area mentioned in the said Government
notification-

And whereas, on inspection of the aforesaid premises, it is noticed
that the objects or goods mentioned in the list appended herewith are
such as are likely to cause risk of fire and are required to be removed
to a place of safety.

Now, therefore, in exercise of the powers conferred on me under sub-
section (2) of section 22 of the Gujarat Fire Prevention and Life Safety
Measures Act, 2013 (Guj. 11 of 2013) hereby give you notice that you
shall forthwith remove the said objects or goods to a place of safety
and submit the report in respect of your having done so to the
undersigned within _____ days*.

Place:
Date:

Signature
Name and Designation of
the Officer competent to
issue notice

(*specify the period considering the urgency to remove the objects
and goods.)

FORM B4,

(See sub-rule (2) of rule 15)

Notice to the owner or occupier to comply

To,

Whereas, by notice No ; dated issued to you by and received by you on you were required to remove forthwith the objects or goods specified in the list appended to the said notice, to a place of safety and to submit a report in respect of you having done so to the undersigned;

And whereas, it is found that you have not complied with the said notice and have not removed forthwith the said objects or goods to a place of safety and they are still lying where they were which is likely to cause the risk of fire.

Now, therefore, in exercise of the powers conferred by sub-section (2) of section 22 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013). I, hereby call upon you to submit your say, if any, addressed to the undersigned so as to reach by or before 5.00 p.m. on as to why the said objects or goods should not be seized or detained or removed by taking assistance of a Police Officer.

Place :

Signature and Designation of the Officer.

Date:

FORM B5

(See rule 16)

Seizure or Detention or Removal Memorandum

To,
Shri or M/s Date and Time
Place of Seizure or Detention or Removal
of objects or goods.

Notice(s) No.
Name and Addresses of Panchas.
(1)
(2)
Name of the Police Officer, if
any, present.,

The following property or objects or goods have been seized or
detained or removed under sub-section (2) of section 4 of the Gujarat
Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013)
for the reasons stated below:—

Serial No	Place from where Seized	Particulars of Seized Property	Quantity	Reasons for Seizure or Detention or Removal
(1)	(2)	(3)	(4)	(5)

Signature of the person from whom seized.

Signature of the Panchas

(1)

(2)

Signature of the Police Officer, if any, present.

Signature

Name and Designation of the
Officer competent to issue notice

Place:

Date:

FORM B6

(See rule 16)

PANCHANAMA

Notice(s) No.

Date and Time

Name of the building or premises and Address.....

Name and Address of the person, in charge and present on the spot.....

Name and Address of the Panchas—

(1) Shri/Smtson/daughter/wife, of
Resident of Age years. Occupation

(2) Shri/Smtson/daughter/wife, of
Resident of Age years. Occupation

We the above panchas, are this..... day called by Shri
..... Designation
Place to witness the act of seizing or detaining or removing
certain property or objects or goods from
..... which
were possessed and exposed in the above mentioned building or premises. In
our presence, the said officer, namely,
seized the following mentioned property which we testify to be correct.

Serial No	Place from where Seized	Particulars of Seized Property or objects or goods	Quantity	Reasons for Seizure or Detention or Removal
(1)	(2)	(3)	(4)	(5)

The Panchanama is read over and explained to us and it is a correct account of what we saw.

Signature
Name and Designation of the
Officer.

Signature of the Panchas.

(1)

(2)

Received the copy of the Panchanama.

Signature of the person, in charge of the building or premises.

FORM B7

(See sub-rule (1) of Rule 17)

Notice for entry and inspection

To,

I, _____ empowered by sub-section (1) of section 24 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013) and sub-rule (1) of rule 25 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013, do hereby give you notice that on expiry of not less than three hours from the time of service of this notice upon you this _____ day at _____ time, I shall enter and inspect your building or premises bearing No. _____ located at _____ for the purpose of ascertaining the adequacy and contravention of fire prevention and life safety measures as required to be provided by or under the provisions of the said Act.

Signature
Name and Designation
of the Officer.

Place: ,
Date:

FORM B8

(See sub-rule (2) of rule 17)

Notice to a Woman in the building or premises
to withdraw therefrom

To,

I, _____ empowered by sub section (1) of section 24 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013) and sub-rule (2) of rule 25 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013, have given a notice to the owner or occupier of building or premises bearing No. _____ located at _____ that on expiry of not less than three hours from the time of service of the notice, on him this _____ day at _____ time, I shall enter and inspect the said building or premises for the purpose of ascertaining the adequacy and contravention of fire prevention and life safety measures as required to be provided by or under the provisions of the said Act. Since you are in this building or premises, I hereby give you this notice that you are at liberty to withdraw therefrom before the aforesaid entry and inspection and you may withdraw now, if you desire to do so.

Signature

Name and designation of the
officer.

Place:

Date:

FORM B9

(See rule 18)

Inspection Report

1. After giving a three hours' notice under sub-section (1) of section 5 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013) to the owner or occupier of _____, I have entered and inspected the said building or premises on _____ at _____ for ascertaining the adequacy or contravention of fire prevention and life safety measures that are provided or are required to be provided in the said building or premises by or under the provisions of the said Act.

2. The type* of occupancy in the said building or premises is as under,—

- (a) Residential
- (b) Educational
- (c) Institutional
- (d) Assembly
- (e) Business
- (f) Mercantile
- (g) Industrial
- (h) Storage
- (i) Hazardous

3. Nature* of building or premises,—

- (a) General Constructional Features
 - Low fire risk-cement concrete or bricked-wall, or
 - Medium fire risk-bricked-work and timber, or
 - High fire risk-mostly timber framed such as timber floors, timber roof, timber-stair-case, etc.
- (b) particulars of the building/premises,—
 - (i) Number of storeys and basement, if any
 - (ii) Number of exits
 - (iii) details of ceiling
 - (iv) Number of stair-cases and whether enclosed or opened
 - (v) Verandah or balconies
 - (vi) Attics, mezzanine floors, lofts, etc.

(vii) Whether prescribed distance in respect of means of escapes is maintained or not.

(c) Details of other structures within 20 meters all around the building and open spaces or approaches for fire vehicle.

Structures

Open spaces

- (i) North
- (ii) South
- (iii) East
- (iv) West

(d) Width of abutting road or street.

(e) Maximum number of occupants, employees, visitors.

(f) Inadequacy or contraventions noticed in the building or premises during inspection are as under,—

- (1)
- (2)
- (3)

Place:

Date:

Signature
Name and designation of the
Inspecting officer.

(*Mention any of these as may be relevant)

65

FORM B10

(See sub-rule (1) of rule 19)

Notice regarding inadequacies or contraventions regarding fire
Prevention and life safety measures noticed during inspection

To,

Whereas, after giving you notice No. _____ dated _____ under sub-section (1) of section 5 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013), the nominated officer has or I have inspected the following building or premises, namely:—

_____ and the following deviations from or contraventions of, the requirements with regard to the fire prevention and life safety measures or inadequacies or non-compliances* of such measures provided or to be provided therein with reference to the height of the building or the nature of activities carried on in such building or premises or part thereof have been reported by the nominated officer or are noticed by me,—

- (1)
- (2)
- (3)

Now, Therefore, in exercise of the powers conferred by section 6 of the said Act, I hereby direct you to undertake the following measures within _____ days after receipt of this notice by you,—

- (1)
- (2)
- (3)

I hereby further direct you to report the compliance in this regard immediately to the undersigned.

Signature

Name and designation of the officer.

Place:
Date:

FORM B11

(See sub-rule (1) of rule 21)

**Notice for Appointment of Fire Safety Officer
under section 12 of the Act**

No.

Dated:

WHEREAS the building/premises bearing No.
located at
is comprised of
.....
and covered under First Schedule of rules.

AND WHEREAS the owner/occupier/an association of such owners
and occupiers were required to appoint a Fire Safety Officer under
section 12 of the Act.

NOW THEREFORE, I
Director /Nominated Authority appointed under the Act, call upon you
to appoint a Fire Safety Officer withindays failing which the
owner or occupier or an association of such owners and occupiers
shall be deemed to be in default jointly and severally and penal action
shall be initiated under sub-section (1) of section 12 of the Act without
any further notice or opportunity.

()
The Regional Fire Officer or the
Chief Fire Officer

Place:

Date:

To

..... the owner/occupier/an association of such
owners and occupiers

FORM B12

(See sub-rule (2) of rule 21)

Certificate of Appointment of Fire Safety Officer

No.

Dated:

Passport size
photograph of the
member attested by
Regional Fire Officer
or the Chief Fire
Officer

Certified that

Shri
son of Shri
resident of

whose photograph appear on the right corner of the certificate, has been appointed under section 12 of The Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Gujarat Act 11 of 2013) and vested with the powers, privileges and immunities of a member of Fire Service with effect from

In the event of any complain or for any other reasons recorded in writing, the Regional Fire Officer or the Chief Fire Officer as the case be may terminate the appointment and take action under the rules and the Act.

Date:
Place:

Signature
Name and Designation of
the Member

Attestation by.....

FORM B13

(See sub-rule (1) of rule 23)

Fire Safety Certificate

No. Dated:

Certified that the (name of the building or premises) at (address) comprised of basement(s) and (upper floors) owned/occupied by (name of the company / name of the owner/occupier)

have complied with the fire prevention and fire safety requirements in accordance with section 18 and verified by the officers concerned of Fire Service on (date of inspection) in the presence of (name and addresses of the owner or his representative) and that the building/premises is fit for occupancy with effect from for a period of years in accordance with rules and subject to compliance of any specific laid by the issuing officer

Issued on

Signature (Name and designation of the authorized signatory)

Place:

Computer ID.....

* Strike out whichever is not applicable.

Endorsement

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to(reasons to be recorded).

(Name and designation of the authorized signatory)

003

FORM B14

(See sub-rule (2) of rule 23)

Application to Grant Fire Safety Certificate

To
The Regional Fire Officer or the Chief Fire Officer

Sub: Application for grant of fire safety certificate in respect of
.....at.....(address of building/premises).

Sir

This is to inform you that a fire safety certificate needs to be issued in
respect of (name of the building)

located at
.....(address of the building)

comprised of
.....and having occupancies as

In this connection it is submitted that all the fire prevention and fire safety
measures as recommended by you vide letter No. dated
Have been provided in the building/premises and para wise compliance
report is enclosed

You are requested to kindly take action as necessary for grant of fire safety
certificate for occupancy of the building/premises.

Place:

Date:

Signature

(Name of the Applicant)

Contact details:

Name in Full.....

Tel. No.

Mobile No.

FORM B15

(See sub-rule (2) of rule 26)

**Certificate for compliance of Fire Prevention
and Life Safety Measures.**

Certified that I have executed the works towards compliance in relation to Fire Prevention and Life Safety Measures to be provided and performed other related activities required to be carried out, in the following building or premises, as required under the provisions of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013).

Description and Location of Building or Premises

Title details of the work and related activities which I or we have executed or performed are mentioned in the list appended herewith.

Place : Signature and Address of the Fire Safety Officer.

Date : Licence No

Signature of the occupier and the owner

[*Note.- For each building a separate certificate is be necessary].

207

FORM C1
(See rule 28)

Form of Declaration By Erector Of A Pandal

Declaration By Erector Of Pandal Under Section 27 Of The Act

I(name of the erector of pandal) having registered office at do hereby declare that the pandal erected at measuring..... meters by meters shall remain in place with effect from to and that fire prevention and fire safety measures as required under rule 40 of the Gujarat Fire Prevantaion and Lief Safety Rules, 2013 have been provided therein and further that the complete erection of pandal and electrical services are in conformity with the standards.

Also, it is declared that no storage/use of the flammable liquid or gases is done in the pandal and that electrical wiring has been done in conformity with Indian Electricity Rules by authorized persons.

I, also, declare that following trained fire fighting staff shall remain on duty during the occupancy of the pandal:-

1.
2.
3.

(Signature of erector of pandal)

Dated:

Place:

FORM C2
(See sub-rule (2) rule 29 & sub-rule (8) rule 31)

Seizure Order

Date & Time _____
Case No. _____

WHEREAS a report has been received from the authorised fire officer dated _____ regarding certain goods/objects that are imminent cause of risk of fire/ obstruction to fire fighting in the premises or building or temprory structure, shamiyana or tent or mandap or pandal erected or owned or occupied by you.

WHEREAS you have failed to carry out the orders of the authorised officer under sub-section (1) of section 27 of the Gujarat Fire Prevantaion and Lief Safety Measures Act, 2013 (Guj. Act 11 of 2013).

AND WHEREAS you have failed to make representation under sub-section (2) of section 27 of the Gujarat Fire Prevantaion and Lief Safety Act, 2013 (Guj. Act 11 of 2013). or the reasons submitted by you vide letter dated _____ are not found satisfactory.

NOW THEREFORE I, _____ (name of the Authority) _____ (designation) empowered under sub-section (3) of section 27 of the Gujarat Fire Prevantaion and Lief Safety Act, 2013 (Guj. Act 11 of 2013). hereby order to seize, detain or remove the encroachment of the following goods/objects for the reasons stated against each.

Sl. No.	Place from where to be seized	Particulars of objects or goods to seized	Quantity	Reasons for seizure and detention

(Signature of Authority) _____
Name and Designation

To
1. _____ (Name and address of the Owner/occupier of the building or premises or pandal).
2. _____
3. _____

909

FORM C3
(See sub-rule (2) rule 29)

Panchnama

Case No. _____
Place _____
Date _____
Time _____

1. Name and address of Owner/occupier _____
2. Name and address of the person present _____
3. Name and Address of the Panchas:
 - A.
 - a) Shri/Smt _____
 - b) S/o.D/o./W/o. _____
 - c) Resident of _____
 - d) Age (Years) _____
 - e) Occupation _____
 - B.
 - a) Shri/Smt _____
 - f) S/o.D/o./W/o. _____
 - g) Resident of _____
 - h) Age (Years) _____
 - i) Occupation _____

We, the above Panchas are this day _____ called
by Shri/Smt. _____ designation _____
Place _____ to _____ witness the act
of seizing of certain objects or goods from _____

_____ address of the
building/premises/pandal which were possessed and exposed in the
premises/building/pandal of the owner/occupier. In our presence, the
said _____ (name and designation of
the officer) seized the following mentioned objects/goods which we
testify to be correct.

Sl. No.	Place from where seized	Particulars of seized objects or goods	Quantity	Reasons for seizure and detention

The Panchnama is read over and explained to us and it is correct account of when we saw.

Signature of Panchas: (Signature of the Authority seizing the goods)

(1) _____
(2) _____

Received the copy of Panchnama. Signature of the owner/occupier

FORM C4

(See sub-rule (3) of rule 29 & sub-rule (9) of rule 31)

Notice for Claiming of Seized Goods

WHEREAS certain objects/goods were seized on _____ (date)
from premises located at _____ (address of the
premises) in case No. _____ dated _____
vide panchnama No. _____ dated _____
under section 27 of the Act

WHEREAS the said objects/goods are now lying at
_____ (address of the premises).

NOW THEREFORE I _____ (name) _____
(Designation) having office at _____ do hereby
call upon you to remove the said objects/goods on any working day
between _____ Hrs to _____ Hrs within _____
days at your risk and cost failing which it shall be presumed that you
don't intend to claim the said objects/goods and the same shall be
disposed off by way of public auction under the provision of sub-
section (8) of section 27 of the Gujarat Fire Prevantaion and Life
Safety Act, 2013 (Guj. Act 11 of 2013). without any further notice.

(Signature)

Name _____

Designation _____

Dated: _____

Place: _____

206

FORM C5

(See rule 30)

No.

Date:

NOTICE

WHEREAS the services of the Gujarat State Fire Service were requisitioned on atHours to assist in the fire fighting and/or rescue operation during the out break of fire at (address of the premises).

WHEREAS (no of appliances) along with members of fire service responded from (name of fire stations) on at hours and returned back to their respective fire stations on..... at..... Hours.

WHEREAS a sum of Rs. _____ towards the deployment of the Fire Service is due to be paid by you.

NOW THEREFORE, I _____ (name) _____ (Designation) call upon you to pay the said amount within _____ days through bank draft payable to Director, Gijarat State Fire Service payable at Gandhinagar.

Signature

()
Director,
Gujarat State Fire Service

To,

FORM C6

(See sub-rule (2) of rule 31)

NOTICE

OFFICE OF SUB-DIVISIONAL MAGISTRATE

No.

Date:

WHEREAS a report has been received from the Director, Gujarat State Fire Service under sub-section (6) of section 27 of the Act regarding removal of encroachment or objects or goods causing a risk of fire or obstruction to fire fighting at _____ (address of the premises).

NOW THEREFORE I, _____ (name)

(Designation) call upon you to show cause within _____ (days) from receipt of this notice under sub-section (6) of section 27 as to why action should not be initiated as necessary under the provisions of the Act.

Signature

Sub-Divisional Magistrate

To,

all

FORM C7

(See sub-rule (3) of rule 31)

Declaration by the promoter or the organizer or the owner or the occupier of permises

No.

Date:

WHEREAS, the undersign promoter or the organizer or the owner or the occupier of permises are intending to use the permises bearing R.S.No./C.S.No./Property No. _____ having the postal address namely:-

In the said permises we intend to use it for the following purpose (describe the purpose) _____

Therefore, as required under sub-section (2) of section 27 of the Gujart Fire Prevention and Life Seafy Measures Act, 2013 (Guj. 11 of 2013) we declare to have made measures as prescribied in the under sub-section (1) of section 27.

The aforesaid permises shall be open for inspection to the authorised officer to access the correctness and adequacy of the measures.

We therefore request to grant necessary permission for the use of the permises.

Signature

**Promoter or the organizer or the owner
or the occupier of permises**

To,

FORM C8

(See sub-rule (3) of rule 31)

Permission to grant use of temporary structure

No. _____

Date: _____

WHEREAS _____ the _____ building/premises bearing

No. _____ located at _____

to be used for the following purpose _____

Whereas, the promoter or the organizer or the owner or the occupier of premises have submitted the declaration dated _____ under sub-rule (3) of rule 31 in form 'C'.

The inspection for the aforesaid premises is carried out on dated _____ by authorised officer.

The permission is granted to use the premises for the aforesaid purpose from date _____ to date _____ with the following conditions.

Signature
Authorised Officer

To,

995

FORM C9

(See sub-rule (10) of rule 31 & sub-rule (1) of rule 36)

FORM OF APPEAL TO THE APPELLATE AUTHORITY

Appeal No. of 20.....

Appellant:

Shri..... Son of Shri.....

resident of

Versus

Municipal Commissioner/Nominated Authority/Director/ Sub
Divisional Magistrate-Respondent Appeal under section 33 of Gujarat
against the notice /order of Shri

..... Nominated Authority/
Sub Divisional Magistrate /Director dated:

Sir,

The Appellant respectfully showeth as under:-

1. Statement of facts.
2. Ground of Appeal.
3. Fee of Rs. 5000/- has been paid vide receipt
No.....dated
4. Appeal is within time.
5. No other Appeal or any matter relating to the subject matter of
this appeal is pending in any court of law.
6. Relief claimed.

Signature of Authorized
representative, if any.

Signature of Appellant

VERIFICATION

I..... the appellant do
hereby declare that what is stated above is true to the best of my
personal knowledge and belief and that I have not suppressed any
material facts.

Verified today, the day of20.....

Place:	Signature of Authorized representative, if any.
Date:	
Signature of Appellant	

FORM D1
(See sub-rule (2) of rule 41)

Form of Fire Report

1. Current date.
2. Fire Report Number.
3. Operational jurisdiction of Fire Station.
4. Information received from.
5. Name of the caller.
6. Phone number of the caller.
7. Full address of the incident place.
8. Date of receipt of call.
9. Time of receipt of call.
10. Time of departure from Fire Station.
11. Approximate distance from Fire Station.
12. Time of arrival at Fire Scene.
13. Nature of call.
14. Date of leaving from fire scene.
15. Time of leaving from fire scene.
16. Type of occupancy
17. Occupancy details in case of others.
18. Category of fire.
19. Type of building.
20. Building details in case of others:
21. Details of affected area.
22. Details if injury.
23. Details of death(s).

Divisional Fire Officer

Disclaimer:

This is a computer generated report. Neither department nor its associates, information providers or content providers warrant or guarantee the timeliness, sequence,

297

FORM D2
(See sub-rule (1) of rule 43)

Order to disconnect electricity / water supply

To,
The Officer In-charge,

Sub. — *Place/building/part thereof bearing No. _____ Located at _____

Sir,

I am to state that by an order No. _____ dated _____ issued under sub-section (1) of section 26 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2007) I, the undersigned had required and directed the persons in possession or in occupation of the

abovesaid place or building or part thereof to remove themselves forthwith from such *place or building or part thereof as due to inadequacy of fire prevention and life safety measures, the condition of such place or building or part thereof is dangerous to the persons or property therein. These persons have however not removed themselves from such *place or building or part thereof in compliance of the order so made and they still continue to be in possession or in occupation thereof.

In the event of non-compliance of the order so made under sub-section (1) of the said section 26, the undersigned is empowered under subsection (2) of the said section 26 to direct the authority responsible for supply of electricity or for supply of water, as the case may be, to disconnect the supply of electricity or water to such *place or building or part thereof and such authority shall comply with such direction.

As the persons in possession or in occupation of the abovementioned *place or building or part thereof have not removed themselves as directed by the said order, there is a non-compliance thereof and I, therefore, direct the authorities executed to disconnect forthwith the supply of electricity or water of the said *place or building or part thereof. Compliance in this behalf may please be reported to me immediately.

Place:

Date:

Signature

Name and designation of the officer.

(*Mention any of these as may be relevant)

FORM D3

(See sub-rule (1) of rule 43)

**Order to remove persons from dangerous place/building to
police officer in-charge.**

To,
The Officer In-charge,

Sub. — *Place/building/part thereof bearing No. _____ Located at _____
Sir,

I am to state that by an order No. _____ dated _____ issued under sub-section (1) of section 26 of the Gujarat Fire Prevention and life Safety Measures Act, 2013 (Guj.11 of 2013) I, the undersigned, had required and directed the persons in possession or in occupation of the abovesaid place or building or part thereof to remove themselves forthwith from such *place or building or part thereof as due to inadequacy of fire prevention and life safety measures, the condition of such place or building or part thereof is dangerous to the persons or property therein. These persons have however not removed themselves from such *place or building or part thereof in compliance of the order so made and they still continue to be in possession or in occupation thereof.

In the event of non-compliance of the order so made under sub-section (1) of the said section 26, the undersigned is empowered under sub-section (2) of the said section 26 to direct any police officer, having jurisdiction in the area, to remove such persons from such *place or building or part thereof and such police officer shall comply with such direction.

The abovementioned *place, building or part thereof is situated within your area of jurisdiction.

As the persons in possession or in occupation of the abovementioned *place or building or part thereof have not removed themselves as directed by the said order, there is a non-compliance thereof and I, therefore, direct you to remove such persons from such *place or building or part thereof and seal the *place or building or part thereof as required under sub-section (3) of section 26 of the said Act. Compliance in this behalf may please be reported to me immediately.

Place:

Signature

Date:

Name and designation of the officer.

(*Mention any of these as may be relevant)

FORM D5

(See rule 46)

Report of Damage Caused to Premises or Property by Fire Officer
during Fire Fighting and Rescue Operations.

Name of the Fire Station:


- (1) Date and time of call received—
- (2) Fire report No. and date—
- (3) Name and Address of the premises where fire occurred—
- (4) Description of property involved—
- (5) Name and Address of the premises to which damage caused—
- (6) Nature and extent of property to which damage caused—
- (7) Description and details of damage caused to the premises or property in the course of fire fighting and rescue operations—
- (8) Reasons for breaking or pulling down the structures, if any—
- (9) Claim of the amount, if any made by the party—
- (10) Name and Designation of the officer of the authority designated under sub-rule (2) of rule 24—
- (11) Remarks-

Submitted through _____

Signature

Name and Designation of the Officer
In-charge of operations.

By order and in the name of the Governor of Gujarat,


(P.L. Sharma)

Officer on Special Duty & Ex-Officio Joint Secretary
to the Government of Gujarat.
Urban Development & Urban Housing Department