## **CORRIGENDUM-1**

[Tender no: NAU/RC/IT/2016-17; Tender: Rate Contract and Procurement of COMPUTER / LAN / UPS / CCTV Equipments]

- 1. Modification in Tender Item No. 5.1 in Procurement Group-5: Voltage Stabilizer of Chapter 7: Specification, Requirement and Scope of Work for Procurements (page no.: 12 in Tender document).
  - a) Inclusion of Output Range: 230V (having +/- 1% variation only)
  - b) Need Servo Stabilizer of 1Kva

**After modification** as mentioned above, Tender Item No. 5.1 in Procurement Group-5: Voltage Stabilizer of Chapter 7: Specification, Requirement and Scope of Work for Procurements(page no.:12 in Tender document) will be as given below:

## **Procurement Group-5: Voltage Stabilizer**

Tender	Item Specification	Quantity
Item		
No.		
5.1	1Kva <b>Servo</b> Stabilizer (Single Phase)	35
	Working Range: 170V-280V	
	Output Range: 230V (having +/- 1% variation only)	
	Servo Stabilizer	

- 2. Modification in Tender Item No. 6.1 in ProcurementGroup-6: Buy Back of 10KVA UPS of Chapter 7: Specification, Requirement and Scope of Work for Procurements (page no.:12 in Tender document).
  - a) Inclusion of Brand Name: APC
  - b) 10KVA UPS must be **compatible with Automatic Transfer Switch** (Electric Ratings: 230V, 32A, 50/60Hz) of APC Company.

**After modification** as mentioned above, Tender Item No. 6.1 in Procurement Group-7: Buy Back of 10KVA UPS of Chapter 7: Specification, Requirement and Scope of Work for Procurements (page no.:12 in Tender document) will be as given below:

Tender	Item Specification	Quantity
Item		
No.		
6.1	Smart Online UPS 10KVA (3 Phase to 1 Phase) or higher	02
	(Brand: APC)	
	<ul> <li>Power Capacity: 8000 Watts / 10000VA or higher</li> </ul>	
	Must be compatible with Automatic Transfer Switch	
	(Electric Ratings: 230V, 32A, 50/60Hz) of APC	
	Company.	
6.2	Buy Back of 2 (Two) Smart-UPS RT 10000 (Brand: APC)	02
	One 10KVA UPS not working.	
	Second 10KVA UPS is working.	